

County of San Diego

DEPARTMENT OF ENVIRONMENTAL HEALTH AND QUALITY

P.O. BOX 129261, SAN DIEGO, CA 92112-9261

Phone: (858) 505-6900 | Fax: (858) 999-8920 | www.sdcdehq.org



POTABLE WATER REQUIREMENTS FOR HOME KITCHEN OPERATIONS

An approved source of potable water is required for all home kitchen operations. If the water will be provided by a regulated water district or small water system where water quality analysis is performed on a routine basis to ensure the water supply meets minimum bacterial and chemical standards, no further action is necessary.

If the water for the home kitchen operation will be obtained from a private water well, the water source must meet the primary water quality standards for a transient, non-community water system. Analytical data results will be required to be submitted to the Department of Environmental Health and Quality prior to approval of a Cottage Food Operation or Microenterprise Home Kitchen Operation. In addition, on an annual basis, home kitchen operations must demonstrate at permit renewal that the water system meets the bacterial water standard. The analysis must be performed for the constituents listed below and must be completed by a California state certified laboratory. Should the water supply not meet the minimum "potable" water quality standards required by law, the home kitchen operation will not be approved until proof of a complying water supply is submitted.

Initial Analysis

The initial analysis shall consist of a total coliform bacteria test which shows the <u>absence</u> of coliform bacteria. In addition, an inorganic chemicals test is required to demonstrate all required constituents tested are at or below the maximum contaminant levels (MCL) shown in the following table.

Inorganic Chemicals	MCL
Aluminum	1.0 mg/L
Antimony	0.006 mg/L
Arsenic	0.010 mg/L
Barium	1.0 mg/L
Beryllium	0.004 mg/L
Cadmium	0.005 mg/L
Chromium (Total)	0.05 mg/L
Cyanide	0.15 mg/L
Fluoride	2.0 mg/L
Mercury	0.002 mg/L
Nickel	0.1 mg/L
Nitrate (as N)	10.0 mg/L
Nitrite (as N)	1.0 mg/L
Perchlorate	0.006 mg/L
Selenium	0.05 mg/L
Thallium	0.002 mg/L

Annual Analysis

The annual analysis shall consist of a total coliform bacteria test which shows the <u>absence</u> of coliform bacteria.

STATE APPROVED LABORATORIES FOR WATER QUALITY ANALYSIS

For a list of state approved laboratories for drinking water and/or wastewater analysis, click on the following link: https://waterboards.maps.arcgis.com/apps/webappviewer/index.html?id=bd0bd8b42b1944058244337bd2a4ebfa

Fields of Testing (FOT):

- 101 Microbiology of Drinking Water
- 102 Inorganic Chemistry of Drinking Water
- 103 Toxic Chemical Elements of Drinking Water
- 104 Volatile Organic Chemistry of Drinking Water
- 105 Semi-volatile Organic Chemistry of Drinking Water
- 106 Radiochemistry of Drinking Water

- 107 Microbiology of Wastewater
- 108 Inorganic Chemistry of Wastewater
- 109 Toxic Chemical Elements of Wastewater
- 110 Volatile Organic Chemistry of Wastewater
- 111 Semi-volatile Organic Chemistry of Wastewater
- 112 Radiochemistry of Wastewater
- 113 Whole Effluent Toxicity of Wastewater