

DFM David G. Williamson

DFM Thomas J. White

San Diego Fire-Rescue/Fire Prevention
Bureau

Technical Services, Hazardous Materials
Management



UST & AST SYSTEMS



Permitting

- Underground Tanks- Installations
- Repipes- What Requires a Permit
- Removals
- Temporary Out of Service
- Out of Services

AGENDA



Installations



105.7.7 Flammable and combustible

liquids. A construction permit is required:

- 1. To install, repair or modify a pipeline for the transportation of flammable or *combustible liquids*.
- 2. To install, construct or alter tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries and similar facilities where flammable and *combustible liquids* are produced, processed, transported, stored, dispensed or used

Repipe Permit



Removals



CITY OF SAN DIEGO
1010 SECOND AVENUE, SUITE #300
SAN DIEGO, CA 92101
PHONE: 619-4477 / 619-4443

Hazardous Material Permit Application
San Diego Fire-Rescue Department

FINIS FILE # _____
PERMIT/APPL. NO. _____
RECEIPT # _____
DATE RECEIVED _____

NAME OF FIRM OR BUSINESS:		NAME OF NOT CHASER:					
ADDRESS (NUMBER) (STREET)		MAILING ADDRESS (NUMBER) (STREET)					
CITY TELEPHONE NO.		CITY TELEPHONE NO.					
NAME OF NOT CHASER:		PROVIDE CONTRACTOR LICENSE:					
ADDRESS (NUMBER) (STREET)		EXPIRATION (MONTH OR YEAR) REQUIRED					
CITY TELEPHONE NO.		DATE ISSUED					
CELLULAR PHONE NUMBER		EMAIL					
COMPENSATION/LIABILITY INSURANCE:							
LIST CONTRACTORS OR VENDORS FROM WHOM YOU OBTAIN INSURANCE:							
NO. OF YEARS	WORK PERFORMED PER. RECEIVED PER.	YEAR COMPANY WAS GRANTED (Reference to no. 91)	TYPE OF HAZARDOUS MATERIALS USED	DATE OF EXPIRING ABOVE WORKING BELOW-GROUND	TYPE OF SUPPLY PUMP, PRESSURE, MATERIAL, PRESSURE OR QUALITY	ISSUANCE BY TALLER FROM BUILDING	ISSUANCE PROVIDED FROM PROPERTY LINE
OTHER HAZARDOUS MATERIALS:							
SOIL REMEDIATION:							
REFRIG:							
MEDICAL GAS / COMPRESSED GAS SYSTEM:							
COMMENTS:							
FIRE DEPARTMENT USE ONLY							
DAE	INSPECTOR'S NAME	COMMENTS					
APPLICATION APPROVED _____							
DATE _____							

HVS 888 (Rev. 11-02) THIS APPLICATION IS AVAILABLE IN ALTERNATIVE FORMATS UPON REQUEST

Hazardous Materials Application Form

- Underground tanks temporarily out of service shall have the fill line, gauge opening, vapor return and pump connection secure against tampering. Vent lines shall remain open and be maintained in accordance with Sections 3404.2.7.3 and 3404.2.7.4.- (Tank Vents for normal venting)

Temporary Out of Service

- **Out of service for 90 days.** Above ground & Underground tanks not used for a period of 90 days shall be safeguarded in accordance with all the following or be removed in accordance with Section 3404.2.14:
 - 1. Flammable or *combustible liquids* shall be removed from the tank.
 - 2. All piping, including fill line, gauge opening, vapor return and pump connection, shall be capped or plugged and secured from tampering.
 - 3. Vent lines shall remain open and be maintained in accordance with Sections 3404.2.7.3 and 3404.2.7.4.

Temporary Out of Service

- **Out of service for one year.** Above ground & Underground tanks that have been out of service for a period of one year shall be removed from the ground in accordance with Section 3404.2.14- (Requirements for Removal and Disposal) or abandoned in place in accordance with Section 3404.2.13.1.4.

- **105.6.16 Flammable and combustible liquids.** An operational permit is required:
- To change the type of contents stored in a flammable or *combustible liquid* tank.

Change of Contents

105.2.2 Inspection authorized.

- Before a new operational permit is *approved*, the *fire code official* is authorized to inspect the receptacles, vehicles, buildings, devices, premises, storage spaces or areas to be used to determine compliance with this code or any operational constraints required.
- ❖ The inspections described in this section are necessary for the fire code official to determine that the application for an Operational Permit complies with the code prior to issuing that permit.
- ❖ Operations may not proceed without an Operational Permit

Operational Permits

DFM David G. Williamson

- 619-533-4449 / FAX- 619-544-6806
- Dwilliamson@sandiego.gov

DFM Thomas J. White

- 619-533-4429 / FAX-619-544-6806
- TJWhite@sandiego.gov

www.sandiego.gov/fireandems/inspections/hazard.shtml

Information