



County of San Diego, Planning & Development Services

Self-Certification Frequently Missed Items (TI)

BUILDING DIVISION

1. Plot plan.
2. County specific notes on plans for existing site and building accessibility compliance.
3. Accurate, itemized scope of work description.
4. Room-by-room or space-by-space occupancy classification missing.
5. Room-by-room or space-by-space occupant load analysis missing.
6. Egress/exiting plan missing.
7. Typical accessibility details incomplete or missing.
8. Existing floor plan (separate from proposed).
9. Title-24 either missing, or incomplete due to missing lighting, electrical, plumbing, and/or mechanical.
10. Lighting schedule missing.
11. Light controls missing or not coordinated with T-24 documents.
12. A plan of the existing electrical, mechanical, plumbing systems.
13. Single-line diagram of electrical distribution system is missing.
14. Isometric plumbing plan is missing.
15. Use of adjoining units relative to occupancy separation.

5510 OVERLAND AVE., SUITE 110, SAN DIEGO, CA 92123 • (858) 565-5920 • (888) 336-7553

[HTTP://WWW.SDCPDS.ORG](http://www.sdcps.org)