



FILED
05-21-13
03:30 PM

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Order Instituting Rulemaking to Integrate and Refine Procurement Policies and Consider Long-Term Procurement Plans.

Rulemaking 12-03-014
(March 22, 2012)

**REVISED SCOPING RULING AND MEMO OF THE
ASSIGNED COMMISSIONER AND ADMINISTRATIVE LAW JUDGE**

The Scoping Ruling and Memo in this proceeding was issued on May 17, 2012. That Ruling determined there would be three Tracks in this proceeding. Track 1 (the Local Reliability Track) concluded with Decision (D.) 13-02-015. In Track 2 (the System Needs Track), D.12-12-010 was issued setting forth scenarios to be used for modeling system needs. In Track 3 (the Procurement Rules and Bundled Procurement Track), comments and reply comments have been filed regarding proposed procurement rules. We anticipate a proposed decision on procurement rules in the summer of 2013. No determination is made at this time regarding the timing of utility bundled procurement filings.

A Prehearing Conference (PHC) was held on May 10, 2013. Based on the discussion at the PHC, there is a need to update the scope and schedule of Track 2. The California Independent System Operator (CAISO) is now preparing studies based on the scenarios adopted in D.12-12-010. We expect the CAISO studies to provide information on the system's operating flexibility needs which can help determine whether to authorize further procurement. The CAISO studies are deterministic in nature, meaning that the results will provide us with

fixed values with no associated probability (for example, the amount of Megawatts the system will be short over a given period of time).

Southern California Edison (SCE) is preparing studies based on the Commission-adopted assumption and scenarios. The SCE studies would be used for the same purposes as the CAISO studies. However, the SCE studies are stochastic in nature, meaning that the model output will have a probability distribution with results showing the likelihood of shortage by volume for a given time period. The CAISO intends to complete stochastic studies as well. The Division of Ratepayer Advocates (DRA) and other parties may complete Track 2 studies as well. All of these studies are within the scope of Track 2.

The workings of the CAISO's deterministic studies have been well-vetted with parties through workshops and informal exchanges of information over the last two years. While there is likely to be differences about certain aspects of these studies, they are well-understood and ripe for Commission consideration. By contrast, there has been only one workshop on SCE's stochastic studies and one on the CAISO's stochastic studies (both in May 2013). There is reason to believe that stochastic studies may be more robust than deterministic studies, as stochastic studies look at a range of inputs and the probabilities that such inputs will occur. By contrast, deterministic studies simply choose (hopefully reasonable and likely) data points for many inputs.

We intend to provide parties with the opportunity to present and scrutinize both deterministic and stochastic studies in Track 2. However, we recognize that stochastic studies may not be ripe for Commission adoption at this time.

At the May 10, 2013, SCE indicated that its stochastic studies would be available in September, 2013. The CAISO requested an extended timeframe

(October 2013) to allow its stochastic studies to be presented as well as its deterministic studies. The original Scoping Memo in this proceeding foresaw a decision in Track 2 by the end of 2013. That timeframe is no longer possible. However, it is important to complete Track 2 before underlying data becomes stale.

In seeking to balance time considerations and record development, we will allow stochastic studies if they can be presented within the timeframe below. If this is not possible, it will be an indication that such studies are not sufficiently developed for consideration in this proceeding at this time. The schedule for the remainder of Track 2 will be as follows:

TRACK 2 REVISED SCHEDULE

| | |
|--|--|
| September 20, 2013 | SCE and CAISO ¹ Deterministic and/or Stochastic Studies and Opening Testimony |
| November 1, 2013 | All Other Parties' Opening Testimony and Reply to SCE and CAISO |
| November 15, 2013 | All Parties' Rebuttal Testimony |
| November, 2013 (date to be determined) Commission Courtroom, State Office Building 505 Van Ness Avenue San Francisco, CA 94102 | Prehearing Conference |

¹ If DRA or any other party chooses to file a similar study, they must file it with Testimony no later than this date.

| | |
|--|--|
| December 2 to 6 and December 9 to 13, 2013 Commission Courtroom, State Office Building 505 Van Ness Avenue San Francisco, CA 94102 | Evidentiary Hearings |
| Dates to be determined at hearings | Briefs and Reply Briefs |
| Date of Reply Briefs | Last date to request Final Oral Argument; expected Submission date |
| March 2014 (projected) | Proposed Decision |
| No less than 30 days after Proposed Decision | Decision on Commission Agenda |

We will also add a Track 4 to the scope of this proceeding at this time. Track 4 will consider the local reliability impacts of a potential long-term outage at the San Onofre Nuclear Power Station (SONGS) generators, which are currently not operational. The CAISO is developing a study to assess both the interim (2018) and long-term (2022) local reliability needs in the Los Angeles Basin local area and San Diego sub-area resulting from an extended SONGS outage. Parties should note that this differs from the Track 2 CAISO studies, which have scenarios with various SONGS availability over time for system reliability purposes. SCE and San Diego Gas & Electric Company (SDG&E) are also developing studies of local area needs without SONGS. DRA and other parties have indicated that they may also develop their own power flow studies.

The Track 4 inquiry can help inform the magnitude of local capacity requirements with and without SONGS. There also may be some interaction between any needs identified in the incipient Track 4 of this proceeding and any residual operational flexibility needs identified in Track 2 of this proceeding.

Similar to Track 1, building resources to meet local capacity needs is likely to help address systemwide flexibility needs.

Based on the discussion at the PHC, the schedule for Track 4 will be as follows:

TRACK 4 SCHEDULE

| | |
|--|---|
| August 5, 2013 | CAISO Study and Opening Testimony |
| August 26, 2013 | SCE Study and Opening Testimony ² |
| September 23, 2013 | All Parties (except SCE and CAISO) Opening Testimony and Reply to SCE and CAISO |
| October 7, 2013 | All Parties Rebuttal Testimony; final date to request evidentiary hearings; expected Submission date if no evidentiary hearings |
| October 2013 (date to be determined) Commission Courtroom, State Office Building 505 Van Ness Avenue San Francisco, CA 94102 | Prehearing Conference, if needed |
| October 28 – November 1, 2013 Commission Courtroom, State Office Building 505 Van Ness Avenue San Francisco, CA 94102 | Evidentiary Hearings, if needed |
| Dates to be determined | Briefing Schedule, if needed |
| December 1, 2013 or date of Reply Briefs (if applicable), whichever comes later | Last date to request Final Oral Argument |

² If DRA or any other party chooses to file a similar study, they must file it with Testimony no later than this date.

| | |
|--|--|
| Date of Reply Briefs (if applicable) | Last date to request Final Oral Argument (if evidentiary hearings are held) ³ |
| December 2013 | Proposed Decision, if no evidentiary hearings are held |
| February 2013 | Proposed Decision if evidentiary hearings are held |
| No less than 30 days after Proposed Decision | Decision on Commission Agenda |

In Track 2 of this proceeding, an Assigned Commissioner’s Ruling on June 27, 2012 set forth standardized planning assumptions to be used to develop scenarios for consideration of system needs for the next 10 to 20 years. For Track 4, this Scoping Ruling sets forth the assumptions to be used for considering the impacts of interim and long-term local reliability needs in the Los Angeles Basin local area and San Diego sub-area resulting from an extended SONGS outage. The assumptions are in Attachment A to this Ruling.

IT IS RULED that:

1. Evidentiary hearings (EH) may be needed for Track 4 of this proceeding. EHs are not needed for Track 3 of this proceeding.
2. The scope of Track 2 and Track 4 of this proceeding is as stated herein.
3. The assumptions in Attachment A to this Ruling shall be used to study interim (2018) and long-term (2022) local reliability needs in the Los Angeles

³ Rule 13.13 states in applicable part: “In ratesetting and quasi-legislative proceedings in which hearings were held, a party has the right to make a final oral argument before the Commission, if the party so requests within the time and in the manner specified in the scoping memo or later ruling in the proceeding.”

Basin local area and San Diego sub-area resulting from an extended SONGS outage.

4. Administrative Law Judge David M. Gamson shall continue to be the presiding officer in this proceeding.

5. The preliminary determination in Rulemaking 12-03-014 that this proceeding is categorized as ratesetting is again confirmed.

Dated May 21, 2013, at San Francisco, California.

/s/ MICHEL PETER FLORIO

Michel Peter Florio
Assigned Commissioner

/s/ DAVID M. GAMSON

David M. Gamson
Administrative Law Judge

ATTACHMENT A

TRACK 4 ASSUMPTIONS

Background

The San Onofre Nuclear Generating Station (SONGS) has key impacts on the Los Angeles (LA) Basin local area and San Diego sub-area (“SONGS Study Area”).⁴ The following assumptions are established, consistent with the 2012 Long Term Procurement Plan (LTPPs) Scenarios and Assumptions,⁵ the 2012 LTPPs Track 1 Decision,⁶ and the San Diego Gas & Electric Power Purchase Tolling Agreement Decision.⁷ These studies align with recent infrastructure authorizations made by this Commission and the California ISO and will provide a common reference point for any needs both with and without SONGS. We did explicitly acknowledge, however in the Track 2 Decision, that certain revised study assumptions were appropriate, including using a 1-in-10 versus 1-in-2 peak weather forecast for transmission and local area planning and allocation methodologies for assigning Energy Efficiency and Demand Response to busbars.

Study Parameters

Purpose The primary purpose of these studies is to determine the local resource replacement requirements for SONGS, if SONGS remains offline or if we make a policy decision to not pursue relicensing in 2022 when the license expires. A secondary purpose is to ensure local procurement can be optimized to address local capacity needs and flexibility should SONGS need replacement. Other broader studies of local needs such as zonal requirements or off-peak assessments, aside from local capacity requirements, are expected to be taken up by the California ISO (CAISO) in its Transmission Planning Process (TPP).

⁴ Due to the interdependency of the LA Basin local area and San Diego sub-area on the SONGS facility, one comprehensive set of studies will be conducted. Collectively this area is referred to as the SONGS Study Area.

⁵ See D.12-12-010, available [here](#).

⁶ See D.13-02-015, available [here](#).

⁷ See D.13-03-029, available [here](#).

Cases We request that the CAISO model three separate cases. The first is 2022 without SONGS; the second is 2022 with SONGS; and the third is 2018 without SONGS.

Assumptions The assumptions listed in the summary table below are consistent with the approach of the 2012 LTPP and should be used in the analysis of the SONGS Study Area. The assumptions reflect any adjustments necessary to be consistent with the scope of this analysis, for example, locational uncertainty of a resource, and geographical aggregations to match the study area. The derivations of these assumptions from earlier decisions are described later in this document.

To clearly identify where and how assumptions shall be used in the studies, assumptions are generally classified into three categories. The first category, “Model input”, consists of assumptions that shall be embedded in the model as an input. The second category, “First Contingency”, consists of assumptions representing resources that can be relied upon to address a post-first contingency situation. The studies shall model “First Contingency” resources as addressing the first contingency to prepare for a second contingency. The third category, “Second Contingency”, consists of assumptions representing residual resources that could be used to meet subsequent post-contingency needs. “Second Contingency” resources are not modeled but would be accounted for as potential resources to address any residual need identified by a second contingency condition in the studies.

For example, incremental energy efficiency (EE) is a “Model input” assumption because it is accounted for by debiting the load input assumption. Currently funded fast response (30 minute or less) demand Response (DR) programs fit the “First Contingency” category because they can address a post first-contingency condition and would be triggered once the first major item trips offline. Price responsive and day-ahead DR programs or DR programs outside of the areas of most concern fit the “Second Contingency” category. We expect that those programs could become more capable of meeting needs by 2022, but without action to make that a reality, we cannot assume that they can meet the identified problem. The study results shall provide a broad assessment of local area needs that inform the programs of “Second Contingency” resources such that they can adapt to meet the residual need.

Not all resource types will be available or effective in meeting identified needs based on location or type of need. For example, demand response cannot exceed the forecast load at any given busbar, nor should industrial demand response programs be modeled at a busbar without industrial load.

Summary Table - SONGS Study Area Input Assumptions for 2018 and 2022

| Variable | 2018 | | | 2022 | | |
|---------------------------------|-------------------------------|-------------------|--------------------|-------------------------------|-------------------|--------------------|
| | Model input | First Contingency | Second Contingency | Model input | First Contingency | Second Contingency |
| Load | 27,522 MW | - | - | 28,973 MW | - | - |
| Inc EE | 524 MW | - | - | 933 MW | - | - |
| DR | - | 189 MW | 997 MW | - | 189 MW | 997 MW |
| Inc CHP | 0 MW | - | - | 0 MW | - | - |
| Inc small PV installed capacity | - | - | 477 MW | - | - | 616 MW |
| RPS Portfolio | Commercial | - | - | Commercial | - | - |
| Resource additions | 160 MW | - | 2,098 MW | 160 MW | - | 2,098 MW |
| Resource retirements | All OTC plus 1,883 MW non-OTC | - | - | All OTC plus 1,883 MW non-OTC | - | - |
| Transmission | All ISO approved upgrades | - | - | All ISO approved upgrades | - | - |

Load

The 2018 and 2022 1-in-10 peak load for the local area with 1-in-5 system load is appropriate to use. The mid-range economic and demographic assumptions are appropriate to use. The most recent forecasts are in the 2012 Integrated Energy Policy Report, August 2012 revision, forms 1.5c & d.⁸

⁸ http://www.energy.ca.gov/2012_energy_policy/documents/demand-forecast/Mid_Case_LSE_and_Balancing_Authority_Forecast.xls

Peak Load

| | 1-in-5 peak MW | | 1-in-10 peak MW | |
|---------------------------------|-------------------|-------------|--------------------|-------------|
| | <u>2018</u> | <u>2022</u> | <u>2018</u> | <u>2022</u> |
| LA Basin Local Area | 21,174 | 22,187 | 21,870 | 22,917 |
| SDG&E Service Area ⁹ | 5,528 | 5,922 | 5,652 | 6,056 |
| Total | 26,702 | 28,109 | 27,522 | 28,973 |

Incremental Energy Efficiency

Future energy efficiency programs are generally not crafted to specific locations. Therefore we adopt the low level of savings for use in this set of studies to account for this uncertainty, even though across the SCE and SDG&E areas we expect the mid-level of savings to occur.

Values in the table below show the low level of savings from the incremental EE forecast associated with the 2012 IEPR Update¹⁰ and the adjustment for the SONGS Study Area, aggregated from busbar value forecasts consistent with the allocation methodology adopted in D.12-12-010.

Low Level of Incremental EE Savings in MW

| <u>IOU area</u> | <u>2018</u> | <u>2022</u> | <u>Study area</u> | <u>2018</u> | <u>2022</u> |
|-----------------|-------------|-------------|-------------------|-------------|-------------|
| SCE | 556 | 973 | LA Basin | 425 | 746 |
| SDG&E | 99 | 187 | San Diego | 99 | 187 |
| SCE + SDG&E | 655 | 1,160 | SONGS Study Area | 524 | 933 |

⁹ There is no load at the Imperial Valley part of the Greater Imperial Valley-San Diego local area, therefore the SDG&E Service Area load is identical to the San Diego sub-area.

¹⁰ http://www.energy.ca.gov/2012_energypolicy/documents/demand-forecast/IUEE-CED2011_results_summary.xls

Demand Response

The Commission identified 200 MW of DR resources in 2022 in the LA Basin in the Track 1 Decision (13-02-015), and 219 MW in 2020 in the San Diego sub-area in the Power Purchase Tolling Agreement (PPTA) Decision (13-03-029). The Track 2 Scenarios and Assumptions Decision of this proceeding (D.12-12-010), identified the IOU Annual Load Impact Reports as the data source for DR projections.

As an interim approach for better quantifying and assessing DR for local reliability purposes in the LA Basin, we establish that fast¹¹ DR located at the most effective LA Basin locations shall be modeled as a “First Contingency” resource, i.e. a resource that can be relied upon post-first contingency to prepare for the second contingency. This amount of DR, 173 MW, is roughly consistent with the amount of DR identified in the Track 1 Decision, 200 MW. To be consistent with the 2012 Load Impact Report, the remaining amount of LA Basin DR forecasted in the report shall be accounted for as a “Second Contingency” resource, i.e. a resource that is available to prepare for subsequent contingencies.

The ISO has identified the most effective substations where DR should be located, as described in the table below.¹²

LA Basins Most Effective Locations For Mitigating Contingencies

| |
|------------|
| Alamitos |
| Barre |
| Del Amo |
| Ellis |
| Johanna |
| Lewis |
| Santiago |
| Viejo |
| Villa Park |

¹¹ Fast demand response programs in this context are programs that respond to dispatch instructions within 30 minutes or less, including notification time to customers.

¹² ISO studies as part of the 2012/13 Transmission Planning Process examined grid conditions in light of a continued SONGS outage. See [here](#) starting at page 170.

As an interim approach for better quantifying and assessing DR for local reliability purposes in the San Diego sub-area, we establish that fast DR located anywhere in San Diego shall be modeled as a “First Contingency” resource, i.e. a resource that can be relied upon post-first contingency to prepare for the second contingency. This amount of DR, 16 MW, is consistent with the approach that fast DR has the attributes required to address contingencies within the appropriate response timeframe. To be consistent with the San Diego PPTA Decision, the remaining amount of San Diego sub-area DR accounted for as a “Second Contingency” resource, i.e. a resource that is available to prepare for subsequent contingencies, shall be the difference between 219 and 16, or 203 MW. This amount of total DR is significantly greater than the amount of DR forecasted by the Load Impact Reports and therefore represents new programs or substantial program growth in San Diego by 2022.

For the San Diego sub-area, DR located anywhere within the area is considered effective for mitigating contingencies.

The following table summarizes the demand response projections relevant to the SONGS study area.

Demand Response Projections in MW

| <u>IOU area¹³</u> | <u>2018</u> | <u>2022</u> | <u>Study area, DR</u> <u>type¹⁴</u> | <u>2018</u> | <u>2022</u> |
|------------------------------|-------------|-------------|---|-------------|-------------|
| SCE | 1,252 | 1,252 | LA Basin "First Contingency" | 173 | 173 |
| | | | LA Basin "Second Contingency" | 794 | 794 |
| SDG&E | 75 | 77 | San Diego "First Contingency" | 16 | 16 |
| | | | San Diego "Second Contingency" | 203 | 203 |
| SCE + SDG&E | 1,327 | 1,329 | SONGS Study Area "First Contingency" | 189 | 189 |
| | | | SONGS Study Area "Second Contingency" | 997 | 997 |

This set of assumptions maintains consistency with recent Commission decisions, while also realizing the inherent locational uncertainties associated with programs for which we expect continued development and improvement. This also leaves room for program growth and system changes while acknowledging for the first time in local capacity requirement studies non-zero levels of demand response.

¹³ Values based on 2012 Load Impact Reports.

¹⁴ Values consistent with the LTPP Track 1 Decision 13-02-015 and the San Diego PPTA Decision 13-03-029.

Incremental Combined Heat and Power

For incremental combined heat and power programs, we maintain the current Track 2 assumption of no incremental combined heat and power.

Incremental Small Photovoltaics

For incremental small photovoltaics (PV), we assume up to an installed capacity of 1,300 MW of customer-side incremental PV by 2022, ISO-wide, consistent with D. 12-12-010. This capacity represents projected customer-side PV incremental to the amount embedded in the IEPR demand forecast. This incremental amount makes up for the shortfall in reaching the 3,000 MW CSI program target embedded in the IEPR demand forecast, and also reflects projected growth in customer-side PV due to Net Energy Metering expansion.

To adapt the ISO system-wide projection of 1,300 MW installed capacity to the SONGS study area, we adjusted this amount by load share ratios to estimate the amount of PV to allocate to the LA Basin and the San Diego LCR areas. Furthermore, the installed capacity amounts are adjusted by peak demand impact factors to yield an “NQC” value. These factors come from California Solar Initiative Impact Reports and are consistent with the factors used for small PV that is embedded within the IEPR demand forecast. The tables below summarize these amounts.

2018 customer-side incremental PV

| <u>Demand</u> ¹⁵ | <u>MW</u> | <u>Installed capacity</u> | <u>MW</u> | <u>Peak demand impact factor</u> ¹⁶ | <u>NQC MW</u> |
|-----------------------------|-----------|---------------------------|-----------|--|---------------|
| ISO Area | 53,606 | ISO Area | 1,011 | - | - |
| LA Basin Local Area | 20,135 | LA Basin | 380 | 0.45 | 171 |
| SDG&E Service Area | 5,167 | San Diego | 97 | 0.46 | 45 |
| | | LA Basin + San Diego | 477 | - | 216 |

2022 customer-side incremental PV

| <u>Demand</u> | <u>MW</u> | <u>Installed capacity</u> | <u>MW</u> | <u>Peak demand impact factor</u> | <u>NQC MW</u> |
|---------------------|-----------|---------------------------|-----------|----------------------------------|---------------|
| ISO Area | 56,245 | ISO Area | 1,300 | - | - |
| LA Basin Local Area | 21,098 | LA Basin | 488 | 0.45 | 219 |
| SDG&E Service Area | 5,536 | San Diego | 128 | 0.46 | 59 |
| | | LA Basin + San Diego | 616 | - | 278 |

¹⁵ From 2012 IEPR Update demand forecast, Aug 2012, Form 1.5b, 1 in 2 peak loads for 2018 and 2022.

¹⁶ From Itron's CPUC California Solar Initiative 2010 Impact Evaluation Report, Table C-2.

The location where customer-side PV will get built is difficult to predict, therefore the capacity amounts described here will be modeled as “Second Contingency” resources. The ISO shall determine the most effective busbars where customer-side PV should be located in order to address those contingencies. Once those locations are identified, the Commission can then direct customer-side generation programs, like the California Solar Initiative or other efforts, to target those locations.

RPS Portfolio

The Renewable Net Short (RNS) for a 2018 LTPP Scenario Base Case Scenario run is 20,572 GWh. This 2018 RPS was calculated using the August 2012 Integrated Energy Policy Report (IEPR) statewide retail sales forecast of 287,109 GWh and the accompanying “Non RPS Deliveries” 12,443 GWh amount, deriving a “Retail Sales for RPS” amount of 274,666 GWh.

The “Additional Energy Efficiency” amount of 11,137 GWh, consistent with the mid value from the 2012 LTPP, was provided by the Energy Commission, which is an additional Energy Efficiency value composed of the 2012 IEPR Update for the IOUs and the 2011 IEPR for the POU. The “Additional Rooftop PV” amount of 1,679 GWh for 2018 was taken from the CPUC’s LTPP “Scenario Tool”. Subtracting these additional EE and PV GWh amounts from the Retail Sales for RPS figure (Chart 1, line3) provides the 2018 “Adjusted Statewide Retail Sales for RPS” figure of 261,850 GWh.

CPUC Decision 11-12-020, Ordering Paragraph 3, indicates that the 2018 RPS target is 29% of adjusted retail sales. As such, the “Total Renewable Energy Needed for RPS” (261,850 GWh x 29%) results in 75,937 GWh. Netting out the “Total Existing Renewable Generation for CA RPS” amount of 55,364 GWh from the renewable energy needed results in a “Total Renewable net Short to meet 33% RPS in 2018” of 20,572 GWh.

Chart 1: 2022 RNS calculation & 2018 RNS calculation

| | All Values in GWh for the Year 2022 | Formula | 2022 Base | | All Values in GWh for the Year 2018 | Formula | 2018 Base |
|----|---|-------------------|-----------------|----|--|-------------------|-----------------|
| 1 | Statewide Retail Sales - June 2012 IEPRI2 Final | | 301,384.0 | 1 | Statewide Retail Sales - August 2012 IEPRI2 Final | | 287,109.0 |
| 2 | Non RPS Deliveries (CDWR, WAPA, MWD) | | 12,530.0 | 2 | Non RPS Deliveries (CDWR, WAPA, MWD) | | 12,443.0 |
| 3 | Retail Sales for RPS | 3=1-2 | 288,854.0 | 3 | Retail Sales for RPS | 3=1-2 | 274,666.0 |
| 4 | Additional Energy Efficiency | | 19,543.0 | 4 | Additional Energy Efficiency | | 11,137.0 |
| 5 | Additional Rooftop PV | | 2,158.8 | 5 | Additional Rooftop PV | | 1,679.1 |
| 6 | Additional Combined Heat and Power | | - | 6 | Additional Combined Heat and Power | | - |
| 7 | Adjusted Statewide Retail Sales for RPS | 7=3-4-5-6 | 267,152.2 | 7 | Adjusted Statewide Retail Sales for RPS | 7=3-4-5-6 | 261,849.9 |
| 8 | Total Renewable Energy Needed For RPS | 8=7* 33% | 88,160.2 | 8 | Total Renewable Energy Needed For RPS | 8=7* 29% | 75,936.5 |
| | Existing and Expected Renewable Generation | | | | Existing and Expected Renewable Generation | | |
| 9 | Total In-State Renewable Generation | | 40,304.7 | 9 | Total In-State Renewable Generation | | 40,304.7 |
| 10 | Total Out-of-State Renewable Generation | | 13,950.0 | 10 | Total Out-of-State Renewable Generation | | 13,950.0 |
| 11 | Procured DG (not handled in Calculator) | | 1,109.7 | 11 | Procured DG (not handled in Calculator) | | 1,109.7 |
| 12 | Total Existing Renewable Generation for CA RPS | 12=9+10+11 | 55,364.4 | 12 | Total Existing Renewable Generation for CA RPS | 12=9+10+11 | 55,364.4 |
| 13 | Total RE Net Short to meet 33% RPS In 2022 (GWh) | 13=8-12 | 32,795.8 | 13 | Total RE Net Short to meet 33% RPS In 2018 (GWh) | 13=8-12 | 20,572.1 |

The orange highlighted cells in Chart 2 represent those 2012 LTPP Base Case scenario projects that are included in the RPS Calculator which satisfy the smaller RNS of 20,572 GWh estimated herein for 2018. Note that most of the projects that are pulled into the 2018 LTPP Base Case Scenario are on existing transmission lines; one project would require a new transmission line (Merced); and 10 out-of-state Renewable Energy Credit only projects fill-in the rest of the portfolio. No generic projects¹⁷ are forecasted to be required in ordered to fill the 2018 RNS. As expected, the projects that fill the 2018 LTPP Base Case RNS are a subset of the projects that filled the 2022 LTPP Base Case RNS.

¹⁷ A generic project is either lacking a complete application for a major environmental review, or an executed contract.

Chart 2: Projects from the LTPP 2022 Base Case Scenario; and highlighted projects from the 2018 Base Case Scenario

| The 327 projects which satisfy the 2022 LTPP Base Case (RNA of 32,796 GWh) | | | | | | | | | | | |
|--|-----------|------------|------------|------------|------------|------------|---------|----------------------------|-------------------------------|--------------------------------|--|
| *The 180 highlighted projects that satisfy the smaller 2018 LTPP Base Case (RNS of 20,572 GWh) | | | | | | | | | | | |
| Project ID - On Exiting Transmission | | | | | | | | Project ID - Minor Upgrade | Project ID - New Transmission | Project ID - Out-Of-State RECs | Generic Projects - Minor Upgrades & New Transmission |
| POU - LA5 | LDPV_2622 | LDPV_2443 | LDPV_11516 | LDPV_9657 | LDPV_17656 | LDPV_8432 | SC7018 | SD0915 | SC5008 | POU - SMUD1 | st26180 |
| POU - MID1 | LDPV_6362 | LDPV_2926 | LDPV_11257 | LDPV_9825 | LDPV_17747 | LDPV_15152 | SC7019 | PG7084 | SC5075 | SD1102 | REAT*0602549150 |
| POU - IID1 | LDPV_4802 | LDPV_1173 | LDPV_11466 | LDPV_4477 | LDPV_7996 | LDPV_8652 | SC7021 | PG5122 | PG6013 | SC3007 | REAT*06099001 |
| POU - IID2 | LDPV_2292 | LDPV_3873 | LDPV_11326 | LDPV_9516 | LDPV_7937 | LDPV_8462 | SCE TBD | PG5123 | PG5131 | SC7029 | REAT**06095006 |
| POU - IID3 | LDPV_4557 | LDPV_5343 | LDPV_11526 | LDPV_8156 | LDPV_9447 | LDPV_15232 | PG7071 | PG5124 | | PG5115 | REAT*06025008 |
| POU - Ana1 | LDPV_5042 | LDPV_11616 | LDPV_11065 | LDPV_9947 | LDPV_10256 | LDPV_15212 | PG5143 | PG5090 | | PG5103 | REAT*06025009 |
| POU - Ana2 | LDPV_992 | LDPV_3525 | LDPV_11436 | LDPV_3677 | LDPV_9326 | LDPV_14012 | PG2037 | PG1046 | | PG5038 | REAT*0602543965 |
| POU - SVP1 | LDPV_1662 | LDPV_11766 | LDPV_11244 | LDPV_3566 | LDPV_9466 | SD0405 | PG5100 | PG5141 | | PG7038 | geo_9 |
| POU - SVP2 | LDPV_2512 | LDPV_11136 | LDPV_11696 | LDPV_7496 | LDPV_9387 | SD0915 | PG6004 | SD0913 | | PG7036 | 03Aug2008_106 |
| POU - SVP3 | LDPV_2272 | LDPV_11297 | LDPV_11076 | LDPV_6236 | LDPV_9377 | SD1002 | PG6005 | SD1001 | | PG7037 | REAT60370034 |
| POU - SVP4 | LDPV_2462 | LDPV_5723 | LDPV_11034 | LDPV_8136 | LDPV_9737 | SD1003 | PG5141 | | | | REAT*06071012 |
| LDPV_227 | LDPV_4692 | LDPV_11364 | LDPV_6164 | LDPV_10216 | LDPV_9487 | SC3012 | PG5083 | | | | REAT**06047002 |
| LDPV_27 | LDPV_5502 | LDPV_2576 | LDPV_4075 | LDPV_2225 | LDPV_8027 | SC6003 | PG6013 | | | | REAT**06047001 |
| LDPV_97 | LDPV_4492 | LDPV_4944 | LDPV_10976 | LDPV_9577 | LDPV_8196 | SC5004 | PG6000 | | | | REAT**06071002 |
| LDPV_326 | LDPV_3662 | LDPV_11606 | LDPV_7624 | LDPV_8316 | LDPV_8216 | SC5003 | PG6011 | | | | REAT*06071010 |
| LDPV_37 | LDPV_1512 | LDPV_11416 | LDPV_11374 | LDPV_7114 | LDPV_15046 | SC5005 | PG5082 | | | | REAT*06071015 |
| LDPV_567 | LDPV_6532 | LDPV_11405 | LDPV_11537 | LDPV_7924 | LDPV_7906 | SC5012 | PG5084 | | | | REAT07146805 |
| LDPV_114 | LDPV_4062 | LDPV_11427 | LDPV_4174 | LDPV_8124 | LDPV_15196 | SC5006 | PG5089 | | | | REAT*0605111667 |
| LDPV_596 | LDPV_2992 | LDPV_11307 | LDPV_2707 | LDPV_9927 | LDPV_8512 | SC5010 | PG5095 | | | | |
| LDPV_46 | LDPV_3072 | LDPV_11545 | LDPV_8165 | LDPV_8016 | LDPV_17466 | SC5077 | PG2028 | | | | |
| LDPV_757 | LDPV_6752 | LDPV_11555 | LDPV_9345 | LDPV_10245 | LDPV_8632 | SC5071 | PG6003 | | | | |
| LDPV_532 | LDPV_3142 | LDPV_11637 | LDPV_9355 | LDPV_9786 | LDPV_14882 | SC5072 | PG5088 | | | | |
| LDPV_202 | LDPV_1992 | LDPV_11666 | LDPV_7156 | LDPV_10047 | LDPV_15222 | SC5070 | PG2042 | | | | |
| LDPV_1262 | LDPV_4132 | LDPV_11357 | LDPV_5917 | LDPV_7956 | LDPV_8572 | SC5019 | PG5085 | | | | |
| LDPV_5667 | LDPV_5432 | LDPV_11746 | LDPV_8294 | LDPV_9476 | LDPV_8402 | SC5073 | PG5081 | | | | |
| LDPV_557 | LDPV_2252 | LDPV_11484 | LDPV_9686 | LDPV_10076 | LDPV_14952 | SC5074 | PG6001 | | | | |
| LDPV_2792 | LDPV_6877 | LDPV_11217 | LDPV_5446 | LDPV_10037 | LDPV_15332 | SC5050 | PG6002 | | | | |
| LDPV_4417 | LDPV_1832 | LDPV_11287 | LDPV_1705 | LDPV_8327 | LDPV_15252 | SC5051 | PG5131 | | | | |
| LDPV_4422 | LDPV_1812 | LDPV_11625 | LDPV_9766 | LDPV_17426 | LDPV_15072 | SC5054 | PG1049 | | | | |
| LDPV_2482 | LDPV_6922 | LDPV_11447 | LDPV_6915 | LDPV_7886 | LDPV_14982 | SC5061 | SD7019 | | | | |
| LDPV_3132 | LDPV_1782 | LDPV_11027 | LDPV_9835 | LDPV_8277 | LDPV_15052 | SC5063 | SD0505 | | | | |
| LDPV_1102 | LDPV_7392 | LDPV_10996 | LDPV_4516 | LDPV_9967 | LDPV_8532 | SC5064 | SD1009 | | | | |
| LDPV_2432 | LDPV_7212 | LDPV_11117 | LDPV_8105 | LDPV_10125 | LDPV_15082 | SC5068 | SD5037 | | | | |
| LDPV_3602 | LDPV_2302 | LDPV_11395 | LDPV_8115 | LDPV_10207 | LDPV_8382 | SC5080 | | | | | |
| LDPV_1202 | LDPV_3624 | LDPV_7543 | LDPV_9656 | LDPV_10116 | LDPV_8542 | SC7015 | | | | | |
| LDPV_6442 | LDPV_6275 | LDPV_11045 | LDPV_9806 | LDPV_9526 | LDPV_8482 | SC7017 | | | | | |

Additions and Retirements

D.12-12-010 assumed retirements based on facility age (more than 40 years old) and for compliance with the State Policy on Cooling Water Intake Structures. Per the once-through cooling (OTC) Policy, Encina is assumed retired, as are 238 MW of non-OTC generation in the San Diego subarea. The recently authorized repower of the Escondido Energy Center peaking plant is added as a 45 MW unit. These values are the same for 2018 and 2022.

For the LA Basin, no OTC generation is assumed retired in 2018 except for Huntington Beach units 3 & 4 and El Segundo unit 4 (unit 3 is currently being repowered). For 2022, all OTC generation is assumed retired in the LA Basin. In addition to the OTC generation, 1,645 MW of additional resources are assumed retired due to age in 2018 and 2022. This includes the Long Beach peakers, refurbished for operation in 2007, and three facilities owned by Pasadena. Based on Pasadena’s resource plan, 115 MW are added in for both 2018 and 2022 accounting for the replacement of Broadway unit 3 and Glenarm units 1 and 2.

| | | 2018 | 2022 |
|-----------|------------|-------------|-------------|
| LA Basin | Retirement | 1645 | 1645 |
| | Addition | 115 | 115 |
| San Diego | Retirement | 238 | 238 |
| | Addition | 45 | 45 |

Due to locational uncertainty over the other resources recently approved by the Commission in D.12-12-010, and in the San Diego PPTA Decision (D.13-03-029), these resources should be accounted for in meeting “Second Contingency” needs. Between 1400 and 1800 MW in the LA Basin and 298 MW in San Diego are appropriate values.

Transmission Changes

The transmission system should be modeled based on previously and currently approved CAISO upgrades, including those in the recently adopted 2012/2013 Transmission Planning Process.

(END OF ATTACHMENT A)