



San Diego County Fire Protection District

FIRE PROTECTION SYSTEM DEFERRED PLAN SUBMITTAL PROCESS

FIRE ALARM PLANS:

- a. Provide three copies of each item listed below:
 - Fire alarm system drawings
 - Calculation sheets (if not provided on system drawings)
 - Manufacturer specification sheets
- b. Plans shall be reviewed and stamped by a licensed California Fire Protection Engineer prior to SDCFPD review and approval
- c. Delivery methods:
 - **In-person**
 - 1) SDCFPD Counter (5560 Overland Ave, Ste 400, San Diego, CA 92123)
 - OR
 - **Mail** to San Diego County FPD (5560 Overland Ave, Ste 400, San Diego, CA 92123)
Include self-addressed pre-paid envelope(s) with mail submittals

FIRE SPRINKLER PLANS:

- a. Provide three copies of each item listed below:
 - Fire sprinkler system drawings
 - Hydraulic calculation sheets
 - Manufacturer specification sheets
- b. Plans shall be reviewed and stamped by a licensed California Fire Protection Engineer prior to SDCFPD review and approval
- c. Delivery methods:
 - **In-person**
 - 1) SDCFPD Counter (5560 Overland Ave, Ste 400, San Diego, CA 92123)
 - OR
 - **Mail** to San Diego County FPD (5560 Overland Ave, Ste 400, San Diego, CA 92123)
Include self-addressed pre-paid envelope(s) with mail submittals

ALTERNATIVE FIRE SUPPRESSION (AFS) PLANS:

- a. Provide three copies of each item listed below:
 - AFS system drawings
 - Manufacturer specification sheets
- b. Plans shall be reviewed and stamped by a licensed California Fire Protection Engineer prior to SDCFPD review and approval
- c. Delivery methods:
 - **In-person**
 - 1) SDCFPD Counter (5560 Overland Ave, Ste 400, San Diego, CA 92123)
 - OR
 - **Mail** to San Diego County FPD (5560 Overland Ave, Ste 400, San Diego, CA 92123)
 - Include self-addressed pre-paid envelope(s) with mail submittals

EMERGENCY RADIO RESPONDER SYSTEM (ERRCS) PLANS:

- a. Provide three copies of each item listed below:
 - ERRC system drawings
 - Manufacturer specification sheets
- b. Plans shall be reviewed and stamped by a licensed California Fire Protection Engineer prior to SDCFPD review and approval
- c. Delivery methods:
 - **In-person**
 - 1) SDCFPD Counter (5560 Overland Ave, Ste 400, San Diego, CA 92123)
 - OR
 - **Mail** to San Diego County FPD (5560 Overland Ave, Ste 400, San Diego, CA 92123)
 - Include self-addressed pre-paid envelope(s) with mail submittals
- d. For RCS radio frequencies and donor site(s) inquiries, contact the Wireless Services Division (WSD) with the Sheriff's Department.

RESIDENTIAL FIRE SPRINKLER PLANS (NFPA 13D):

- a. Provide two copies of each item listed below:
 - Fire sprinkler system drawings
 - 2-head hydraulic calculation sheets
 - Manufacturer specification sheets
- b. Delivery methods:
 - **In-person**
 - 1) SDCFPD Counter (5560 Overland Ave, Ste 400, San Diego, CA 92123)
 - OR
 - **Mail** to San Diego County FPD (5560 Overland Ave, Ste 400, San Diego, CA 92123)
 - Include self-addressed pre-paid envelope(s) with mail submittals